

SF6 GAS-INSULATED SUBSTATION

Description	Unit	Prototype Value		Prototype Value		Prototype Value	
Rated voltage	Kv	145		230		400	
Rated frequency	Hz	60		60		60	
Rated current	A	3150		4000		4000	
Short-time current	kA	40		63		50	
Rated peak current	kA	100		158		125	
Withstand voltage at industrial frequency	kV	275		460		650	
Lightning impulse withstand voltage	kV	650		1050		1425	

PHONE NUMBER: ☎ 462 625 5833 / 462 625 1093 📞 462 252 8893

www.eprecsa.mx

E-MAIL: ventas@eprecsa.mx

